

CELD TEST RESULTS

DEC 18, 2024 3:16 PM

1:UNLEADED 1
PROBE SERIAL NUM 137096

0.2 GAL/HR TEST
PER: DEC 18, 2024 PASS

2:UNLEADED 2
PROBE SERIAL NUM 260531

0.2 GAL/HR TEST
PER: DEC 18, 2024 PASS

3:PREMIUM
PROBE SERIAL NUM 217696

0.2 GAL/HR TEST
PER: DEC 18, 2024 PASS

4:DIESEL
PROBE SERIAL NUM 245872

0.2 GAL/HR TEST
PER: DEC 18, 2024 PASS

HOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
765 286 1849

DEC 18, 2024 3:16 PM

LEAK TEST REPORT

1:UNLEADED 1
PROBE SERIAL NUM 137096

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6092.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY

HOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
765 286 1849

DEC 18, 2024 3:16 PM

LEAK TEST REPORT

2:UNLEADED 2
PROBE SERIAL NUM 260531

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6142.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

MCOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
765 286 1849

DEC 18, 2024 3:16 PM

LEAK TEST REPORT

3: PREMIUM
PROBE SERIAL NUM 217696

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3015.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY
PRODUCT LEVEL INCREASE

MCOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
765 286 1849

DEC 18, 2024 3:16 PM

LEAK TEST REPORT

4: DIESEL
PROBE SERIAL NUM 245872

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 7866.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY
TEMP CHANGE TOO LARGE