



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 8/2/24

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 2256
Address	7910 IN-3
City	Muncie, IN 47303
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg 1	Red Jacket MLLD		
Reg 2	Red Jacket MLLD		
Prem	Red Jacket MLLD		
Dies	Red Jacket MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular 1	30	15	70 ml	189ml	5 sec	Pass 
2	Regular 2	28	15	110 ml	189ml	3 sec	Pass 
3	Premium	28	13	90 ml	189ml	2 sec	Pass 
4	Diesel	-	-	-	189ml	-	Fail 
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Unable to test diesel bc of too much on the line. Cannot get hooked into plug/filter.

Technician Signature :

