

MCOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
965 286 1849
MAR 30, 2025 3:25 PM
LEAK TEST REPORT

1:UNLEADED 1
PROBE SERIAL NUM 137096
TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6092.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL
0.20 GAL/HR FLAGS:
RECENT DELIVERY

COLD TEST RESULTS
- - - - -
MAR 30, 2025 3:25 PM

1:UNLEADED 1
PROBE SERIAL NUM 137096
0.2 GAL/HR TEST
PER: MAR 30, 2025 PASS

2:UNLEADED 2
PROBE SERIAL NUM 260531
0.2 GAL/HR TEST
PER: MAR 30, 2025 PASS

3:PREMIUM
PROBE SERIAL NUM 217696
0.2 GAL/HR TEST
PER: MAR 7, 2025 PASS

4:DIESEL
PROBE SERIAL NUM 245872
0.2 GAL/HR TEST
PER: MAR 30, 2025 PASS

MCOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
965 286 1849
MAR 30, 2025 3:26 PM
LEAK TEST REPORT

2:UNLEADED 2
PROBE SERIAL NUM 260531
TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6142.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

HCOSIER PETE
7500 ST RD 3
RCYERTON IN 47303
765 286 1849

MAR 30, 2025 3:26 PM

LEAK TEST REPORT

3: PREMIUM
PROBE SERIAL NUM 217696

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3015.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY
PRODUCT LEVEL INCREASE

HCOSIER PETE
7500 ST RD 3
RCYERTON IN 47303
765 286 1849

MAR 30, 2025 3:26 PM

LEAK TEST REPORT

4: DIESEL
PROBE SERIAL NUM 245872

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 7866.3 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY
TEMP CHANGE TOO LARGE