

MCOSIER PETE
7500 ST RD 3
ROYERTON IN 47303
765 286 1849

MAY 5, 2025 5:22 PM

LEAK TEST REPORT

1:UNLEADED 1
PROBE SERIAL NUM 137096

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6092.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY

2:UNLEADED 2
PROBE SERIAL NUM 260531

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6142.6 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST PASS

0.20 GAL/HR FLAGS:
RECENT DELIVERY

3:PREMIUM
PROBE SERIAL NUM 217696

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3015.7 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY

4:DIESEL
PROBE SERIAL NUM 245872

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 7866.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY

5:UNLEADED 1
PROBE SERIAL NUM 137096

TEST STARTING TIME:
MAR 1, 2024 5:41 PM

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6092.0 GAL

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY

TEMP CHANGE TOO LARGE