

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

AUG 16, 2024 6:04 PM

CSLD TEST RESULTS

AUG 16, 2024 6:04 PM

T 1:UNLEADED
PROBE SERIAL NUM 262061

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 230438

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

T 3:K-1
PROBE SERIAL NUM 246066

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

***** END *****

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

AUG 16, 2024 6:04 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 262061

NO TEST DATA AVAILABLE

***** END *****

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

AUG 16, 2024 6:04 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 230438

NO TEST DATA AVAILABLE

***** END *****

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

AUG 16, 2024 6:04 PM

LEAK TEST REPORT

T 3:K-1
PROBE SERIAL NUM 246066

NO TEST DATA AVAILABLE

***** END *****