

SUNOCO  
2005 W MEMORIAL  
MUNCIE IN 47302

DEC 18, 2024 8:00 AM

CSLD TEST RESULTS

DEC 18, 2024 8:00 AM

T 1:UNLEADED  
PROBE SERIAL NUM 262061

0.2 GAL/HR TEST  
PER: DEC 18, 2024 PASS

T 2:PREMIUM  
PROBE SERIAL NUM 230438

0.2 GAL/HR TEST  
PER: DEC 18, 2024 PASS

T 3:K-1  
PROBE SERIAL NUM 246066

0.2 GAL/HR TEST  
PER: DEC 18, 2024 PASS

SUNOCO  
2005 W MEMORIAL  
MUNCIE IN 47302

DEC 18, 2024 5:34 PM

LEAK TEST REPORT

T 1:UNLEADED  
PROBE SERIAL NUM 262061

NO TEST DATA AVAILABLE

\* \* \* \* \* END \* \* \* \* \*

SUNOCO  
2005 W MEMORIAL  
MUNCIE IN 47302

DEC 18, 2024 5:34 PM

LEAK TEST REPORT

T 2:PREMIUM  
PROBE SERIAL NUM 230438

NO TEST DATA AVAILABLE

\* \* \* \* \* END \* \* \* \* \*

SUNOCO  
2005 W MEMORIAL  
MUNCIE IN 47302

DEC 18, 2024 5:34 PM

LEAK TEST REPORT

T 3:K-1  
PROBE SERIAL NUM 246066

NO TEST DATA AVAILABLE

\* \* \* \* \* END \* \* \* \* \*