



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date 7/25/24

HYDROSTATIC SPILL BUCKET INTEGRITY TEST

SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

Facility Name:	Shell
Address:	2005 W Memorial Dr
City, State, Zip Code:	Muncie, IN 47302
Facility I.D. #:	2247

Owner:	JP Food Mart Inc
Address:	10881 Harbor Bay Dr
City, State, Zip Code:	Fortville, IN 46040
Phone #:	

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank Number	1	2	3			
Product Stored	Regular	Premium	Kerosene			
Spill Bucket Capacity	5 gal	5 gal	5 gal			
Manufacturer	OPW	OPW	OPW			
Construction	SW	SW	SW			
Test Type	Hydrostatic	Hydrostatic	Hydrostatic			
Spill Bucket Type	Product	Product	Product			
Liquid and debris removed from spill bucket?	Yes	Yes	Yes			
Visual Inspection (No cracks, loose parts or separation of the bucket from the fill pipe.)	Pass	Pass	Pass			
Tank riser cap included in test?	Yes	Yes	Yes			
Drain valve included in test?	Yes	Yes	Yes			
Starting Level	10.5 "	10.5 "	11 "			
Test Start Time	1:20pm	1:25pm	1:30pm			
Ending Level	10.5 "	10.5 "	11 "			
Test End Time	2:20pm	2:25pm	2:30pm			
Test Period	1 Hr	1 Hr	1 Hr			
Level Change	0	0	0			

Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column

Test Results	Pass	Pass	Pass			
--------------	------	------	------	--	--	--

Comments:

Tester's Name : Josh Rider

Tester's Signature :