



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 7/25/24

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	Shell
Address	2005 W Memorial Dr
City	Muncie, IN 47302
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	22	16	130 ml	189ml	6 sec	Pass 
2	Premium	32	22	310 ml	189ml	5 sec	Pass 
3					189ml	.	
4					189ml	.	
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Technician Signature :

