



5296 Breakers Way, Carmel, IN 46033

Date

7/25/24

PRODUCT LINE TEST

Test Location Information

Name	FID 2247
Address	2005 W Memorial Dr
City	Muncie, IN 47302
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
10:50a	88	0	0.0037	0	0
11:05a	88	0	0.0037	0	0
11:20a	88	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
11:55a	22	0	0.0037	0	0
12:10p	21	-1	0.0037	.0037	.0148
12:25p	20	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 7/25/24

PRODUCT LINE TEST

Test Location Information

Name	FID 2247
Address	2005 W Memorial Dr
City	Muncie, IN 47302
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Ball valve on regular isolated line. Ball valve on premium is completely broken and not usable. Isolation plug needed.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 