

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

SEP 15, 2025 1:21 PM

CSLD TEST RESULTS

SEP 15, 2025 1:21 PM

T 1:UNLEADED
PROBE SERIAL NUM 262061

0.2 GAL/HR TEST
PER: SEP 13, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 230438

0.2 GAL/HR TEST
PER: MAR 10, 2025 PASS

T 3:K-1
PROBE SERIAL NUM 246066

0.2 GAL/HR TEST
PER: SEP 15, 2025 PASS

* * * * * END * * * * *

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

SEP 15, 2025 1:21 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 262061

NO TEST DATA AVAILABLE

* * * * * END * * * * *

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

SEP 15, 2025 1:21 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 230438

NO TEST DATA AVAILABLE

* * * * * END * * * * *

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

SEP 15, 2025 1:22 PM

LEAK TEST REPORT

T 3:K-1
PROBE SERIAL NUM 246066

NO TEST DATA AVAILABLE

* * * * * END * * * * *