

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2247

Facility Name Sumco

Address 8005 W Memorial Dr, Murrie

Operator on Duty Name JN-47302

Contact Number

Contact email

Date of Inspection 05-05-25

Name of the Person Conducting Inspection Nehem Singh

Operator Training current

Operator Training ☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc. ☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection ☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Operator Notified ☒ Yes ☐ No
Operator Notified ☒ Yes ☐ No
Operator Notified ☒ Yes ☐ No
Operator Notified ☒ Yes ☐ No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

Are the Spill Bucket in good condition and free of damage/cracks

Operator Notified ☒ Yes ☐ No
Operator Notified ☒ Yes ☐ No
Operator Notified ☒ Yes ☐ No
Operator Notified ☒ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Operator Notified ☒ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

Operator Notified ☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com