

30 DAYS WALK THROUGH INSPECTION

000
Tanks Data

UST Facility I.D. (FID) #	2247	Contact Number	
Facility Name	Sevco	Contact email	
Address	2005 W Memorial Dr, Muncie,	Date of Inspection	01/23/25
Operator on Duty Name	IN 47302	Name of the Person Conducting Inspection	AKSHIT

Operator Training current

Operator Training ☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form ☐ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection ☒ ATG ☐ TIM ☐ SIR ☐ IC ☐ Other

Make and Model

VR TL 350

Does it have paper?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Fill Ports

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Pipeline/STP Sumps

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No ☐ Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com