

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

FEB 20, 2025 8:01 PM

CSLD TEST RESULTS
- - - - -
FEB 20, 2025 8:01 PM

T 1:UNLEADED
PROBE SERIAL NUM 262061
0.2 GAL/HR TEST
PER: FEB 20, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 230438
0.2 GAL/HR TEST
PER: FEB 20, 2025 PASS

T 3:K-1
PROBE SERIAL NUM 246066
0.2 GAL/HR TEST
PER: FEB 20, 2025 PASS

* * * * * END * * * * *

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

FEB 20, 2025 8:01 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 262061

NO TEST DATA AVAILABLE

* * * * * END * * * * *

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

FEB 20, 2025 8:01 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 230438

NO TEST DATA AVAILABLE

* * * * * END * * * * *

SUNOCO
2005 W MEMORIAL
MUNCIE IN 47302

FEB 20, 2025 8:01 PM

LEAK TEST REPORT

T 3:K-1
PROBE SERIAL NUM 246066

NO TEST DATA AVAILABLE

* * * * * END * * * * *