

30 DAYS WALK THROUGH INSPECTION

oil
Tank Data

UST Facility I.D. (FID) #	2259	Contact Number	
Facility Name	Shell	Contact email	
Address	2535 S Hoyt Ave, Portland, OR	Date of Inspection	08/16/24
Operator on Duty Name	47302	Name of the Person Conducting Inspection	AKSHIT

Operator Training

Operator Training current
Is Registration current with correct owner, operator etc.

Registration/Notification Form
☒ Yes
☐ No

Operator Notified

☒ Yes

☐ No

Release Detection Method

Make and Model
Does it have paper?
Is it in Alarm mode?

Release Detection
☒ MTG
☐ CLM
☐ VRTLS350
☐ SIR
☐ TIC
☐ Other

Operator Notified

☒ Yes

☐ No

Interstitial Monitoring Sensor Status Normal
Necessary Monthly Printout Taken

☒ Yes
☐ No

Operator Notified

☒ Yes

☐ No

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?
Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes
☐ No

Operator Notified

☒ Yes

☐ No

Fill Ports

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes
☐ No

Operator Notified

☒ Yes

☐ No

Pipeline/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☒ Yes
☐ No

Operator Notified

☒ Yes

☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☐ Yes
☒ No

Operator Notified

☒ Yes

☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tankdata@gmail.com

www.tankdata.com