

TANK LEAK TEST HISTORY

T 1:REGULAR

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

AUG 16, 2024 3:38 AM

TEST LENGTH 38 HOURS

STARTING VOLUME = 3359

PERCENT VOLUME = 34.6

TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

TANK LEAK TEST HISTORY

T 2:PREMIUM

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

AUG 16, 2024 9:30 AM

TEST LENGTH 30 HOURS

STARTING VOLUME = 952

PERCENT VOLUME = 16.2

TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

TANK LEAK TEST HISTORY

T 3:DIESEL

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

AUG 16, 2024 12:48 PM

TEST LENGTH 40 HOURS

STARTING VOLUME = 478

PERCENT VOLUME = 8.1

TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

TANK LEAK TEST HISTORY

T 4:KEROSENE

LAST GROSS TEST PASSED:

NO TEST PASSED

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:

AUG 16, 2024 1:58 PM

TEST LENGTH 61 HOURS

STARTING VOLUME = 567

PERCENT VOLUME = 26.4

TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JUL 20, 2024 12:42 PM
TEST LENGTH 10 HOURS
STARTING VOLUME= 3539
PERCENT VOLUME = 36.5
TEST TYPE = CSLD

AUG 16, 2024 3:38 AM
TEST LENGTH 38 HOURS
STARTING VOLUME= 3359
PERCENT VOLUME = 34.6
TEST TYPE = CSLD

JUL 31, 2024 11:26 PM
TEST LENGTH 7 HOURS
STARTING VOLUME= 931
PERCENT VOLUME = 15.8
TEST TYPE = CSLD

AUG 4, 2024 12:31 AM
TEST LENGTH 23 HOURS
STARTING VOLUME= 1072
PERCENT VOLUME = 18.2
TEST TYPE = CSLD

JUL 24, 2024 11:02 AM
TEST LENGTH 114 HOURS
STARTING VOLUME= 1968
PERCENT VOLUME = 33.4
TEST TYPE = CSLD

AUG 1, 2024 12:52 AM
TEST LENGTH 70 HOURS
STARTING VOLUME= 644
PERCENT VOLUME = 10.9
TEST TYPE = CSLD

JUL 31, 2024 3:56 PM
TEST LENGTH 95 HOURS
STARTING VOLUME= 567
PERCENT VOLUME = 26.4
TEST TYPE = CSLD

AUG 9, 2024 7:32 PM
TEST LENGTH 81 HOURS
STARTING VOLUME= 567
PERCENT VOLUME = 26.4
TEST TYPE = CSLD

SHELL
2535 HOYT
MUNCIE IN
765 284 26E9

AUG 16, 2024 5:12 PM

CSLD TEST RESULTS

AUG 16, 2024 5:12 PM

T 1:REGULAR
PROBE SERIAL NUM 517863

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 517864

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

T 3:DIESEL
PROBE SERIAL NUM 636334

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

T 4:KEROSENE
PROBE SERIAL NUM 212514

0.2 GAL/HR TEST
PER: AUG 16, 2024 PASS

SHELL
2535 HOYT
MUNCIE IN
765 284 26E9

AUG 16, 2024 5:12 PM

LIQUID STATUS

AUG 16, 2024 5:12 PM

L 1:N1 SUMP
SENSOR NORMAL

L 2:PREM SUMP
SENSOR NORMAL

L 3:DIESEL SUMP
SENSOR NORMAL

SHELL
2535 HOYT
MUNCIE IN
765 284 26E9

AUG 16, 2024 5:12 PM

LEAK TEST REPORT

T 1:REGULAR
PROBE SERIAL NUM 517863

NO TEST DATA AVAILABLE

SHELL
2535 HOYT
MUNCIE IN
765 284 26E9

AUG 16, 2024 5:12 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 517864

NO TEST DATA AVAILABLE

SHELL
2535 HOYT
MUNCIE IN
765 284 26E9

AUG 16, 2024 5:13 PM

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 636334

NO TEST DATA AVAILABLE

SHELL
2535 HOYT
MUNCIE IN
765 284 26E9

AUG 16, 2024 5:13 PM

LEAK TEST REPORT

T 4:KEROSENE
PROBE SERIAL NUM 212514

NO TEST DATA AVAILABLE