

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	2259	Contact Number	
Facility Name	Shell	Contact email	
Address	2535 S Hoyt Ave, Plencie, IN	Date of Inspection	07/18/12
Operator on Duty Name	47302	Name of the Person Conducting Inspection	AKSUT SANAANA

Operator Training		Registration/Notification Form		Release Detection	
Operator Training current	☐ Yes ☐ No	Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	Release Detection Method	☒ ATG ☐ DIM ☐ SIR ☐ OC ☐ Other
Make and Model					
Does it have paper?	☒ Yes ☐ No				
Is it in Alarm mode?	☒ Yes ☐ No				
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No				
Necessary Monthly Printout Taken	☒ Yes ☐ No				

Spill Buckets		Fill Ports		Operator Notified	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No				
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No				

Fill Ports		Operator Notified	
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No		

Pipe/STP Sumps		Operator Notified	
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No		

Under Dispenser Containments (UDC)		Operator Notified	
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No		

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: _____ Signature: _____ Date: _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com 20220516