



5296 Breakers Way, Carmel, IN 46033

Date

7/24/24

PRODUCT LINE TEST

Test Location Information

Name	FID 2259
Address	2535 S Hoyt Ave
City	Muncie
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
11:20am	79	0	0.0037	0	0
11:35am	78	-1	0.0037	.0037	.0148
11:50am	78	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
2:40pm	69	0	0.0037	0	0
2:55pm	69	0	0.0037	0	0
3:10pm	69	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
3:25pm	37	0	0.0037	0	0
3:40pm	36	-1	0.0037	.0037	.0148
3:55pm	35	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 7/24/24

PRODUCT LINE TEST

Test Location Information

Name	FID 2259
Address	2535 S Hoyt Ave
City	Muncie
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 