



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date 7/24/24

HYDROSTATIC SPILL BUCKET INTEGRITY TEST

SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

Facility Name:	Hoyt Shell
Address:	2535 S Hoyt Ave
City, State, Zip Code:	Muncie, IN 47302
Facility I.D. #:	2259

Owner:	Hoyt Shell
Address:	2535 S Hoyt Ave
City, State, Zip Code:	Muncie, IN 47302
Phone #:	2259

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank Number	1	2	3	4		
Product Stored	Regular	Premium	Diesel	Kerosene		
Spill Bucket Capacity	5 gal	5 gal	5 gal	5 gal		
Manufacturer	OPW	OPW	OPW	OPW		
Construction	SW	SW	SW	SW		
Test Type	Hydrostatic	Hydrostatic	Hydrostatic	Hydrostatic		
Spill Bucket Type	Product	Product	Product	Product		
Liquid and debris removed from spill bucket?	Yes	Yes	Yes	Yes		
Visual Inspection (No cracks, loose parts or separation of the bucket from the fill pipe.)	Fail	Pass	Pass	Pass		
Tank riser cap included in test?		Yes	Yes	Yes		
Drain valve included in test?		Yes	Yes	Yes		
Starting Level	11 "	14 "	14 "	11 "		
Test Start Time		1:30pm	1:30pm	1:35pm		
Ending Level		14 "	14 "	11 "		
Test End Time		2:30pm	2:30pm	2:35pm		
Test Period	1 Hr	1 Hr	1 Hr	1 Hr		
Level Change		0	0	0		

Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column

Test Results

Fail	Pass	Pass	Pass		
------	------	------	------	--	--

Comments: Big gash in regular spillbucket.

Tester's Name : Josh Rider

Tester's Signature :