



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 7/24/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 2259
Address	2535 S Hoyt Ave
City	Muncie
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		
Dies	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	25	340 ml	189ml	5 sec	Pass
2	Premium	26	24	420 ml	189ml	4 sec	Pass
3	Diesel	38	26	820 ml	189ml	5 sec	Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Diesel line held a lot of extra pressure but finally did go into slow flow.

Technician Signature :

