

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 2259

Contact Number

Facility Name Shey

Contact email

Address 2535 Shogt Ave, Newark

Date of Inspection 01/23/25

Operator on Duty Name

IN 47302

Name of the Person Conducting Inspection

AKSHIT

Operator Training current

Operator Training

☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Release Detection Method

Release Detection

☒ ATG

☐ CIM

☐ BIR

☐ IC

☐ Other

Make and Model

VR TLS 350

Does it have paper?

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Fill Ports

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Pipeline/STP Sumps

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Under Dispenser Containments (UDC)

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

☐ No

Operator Notified

☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com