

SHELL
2535 HOYT
MUNCIE IN
765 284 2659

JUL 2, 2025 1:31 PM

CSLD TEST RESULTS

JUL 2, 2025 1:31 PM

T 1:REGULAR
PROBE SERIAL NUM 517863

0.2 GAL/HR TEST
PER: JUL 2, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 517864

0.2 GAL/HR TEST
PER: JUL 2, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 636334

0.2 GAL/HR TEST
PER: JUL 2, 2025 PASS

T 4:KEROSENE
PROBE SERIAL NUM 212514

0.2 GAL/HR TEST
PER: JUL 2, 2025 PASS

SHELL
2535 HOYT
MUNCIE IN
765 284 2659

JUL 2, 2025 1:32 PM

LIQUID STATUS

JUL 2, 2025 1:32 PM

L 1:NL SUMP
SENSOR NORMAL

L 2:PREM SUMP
FUEL ALARM

L 3:DIESEL SUMP
SENSOR NORMAL