

SHELL
2535 HOYT
MUNCIE IN
765 284 2659

SEP 15, 2025 12:26 PM

CSLD TEST RESULTS

SEP 15, 2025 12:26 PM

T 1:REGULAR
PROBE SERIAL NUM 517863

0.2 GAL/HR TEST
PER: SEP 15, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 517864

0.2 GAL/HR TEST
PER: SEP 15, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 636334

0.2 GAL/HR TEST
PER: SEP 15, 2025 PASS

T 4:KEROSENE
PROBE SERIAL NUM 212514

0.2 GAL/HR TEST
PER: SEP 15, 2025 PASS

SHELL
2535 HOYT
MUNCIE IN
765 284 2659

SEP 15, 2025 12:26 PM

LIQUID STATUS

SEP 15, 2025 12:26 PM

L 1:NL SUMP
SENSOR NORMAL

L 2:PREM SLMP
FUEL ALARM

L 3:DIESEL SUMP
SENSOR NORMAL