

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

JUL 5, 2024 5:24 PM

CSLD TEST RESULTS

JUL 5, 2024 5:24 PM

T 1:UNL 1
T 2:UNL 2
PROBE SERIAL NUM 170598

0.2 GAL/HR TEST
PER: JUL 5, 2024 PASS

T 3:PREM
PROBE SERIAL NUM 755283

0.2 GAL/HR TEST
PER: JUL 5, 2024 PASS

T 4:DSL
PROBE SERIAL NUM 753605

0.2 GAL/HR TEST
PER: JUL 5, 2024 PASS

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

JUL 5, 2024 5:24 PM

LIQUID STATUS

JUL 5, 2024 5:24 PM

L 1:UNL STP
SENSOR NORMAL

L 2:PREMSTP
SENSOR NORMAL

L 3:DSL STP
SENSOR NORMAL

L 4:UNL INT
SENSOR NORMAL

L 5:SPLIT INT
SENSOR NORMAL

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND.IN

JUL 5, 2024 5:24 PM

LEAK TEST REPORT

T 1:UNL 1
PROBE SERIAL NUM 170598

NO TEST DATA AVAILABLE

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND.IN

JUL 5, 2024 5:24 PM

LEAK TEST REPORT

T 2:UNL 2
PROBE SERIAL NUM 061470

NO TEST DATA AVAILABLE

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND.IN

JUL 5, 2024 5:24 PM

LEAK TEST REPORT

T 3:PREM
PROBE SERIAL NUM 755283

NO TEST DATA AVAILABLE

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND.IN

JUL 5, 2024 5:24 PM

LEAK TEST REPORT

T 4:DSL
PROBE SERIAL NUM 753605

NO TEST DATA AVAILABLE

* * * * * END * * * * *