

PO BOX 335
CORYDON, IN 47112
812-946-6547
AJPETROLEUM@AOL.COM



A&J PETROLEUM

FID	Facility Name Sample St Amoco
Address 1338 Sample St	City South Bend
Zip Code 46619	Date of Test 1/04/2024

Line Tightness Test

Tank	1	2	3	4	5
Product	UNL	PREM	DSL		
Piping Material	FLEX	FLEX	FLEX		
Piping Diameter	1.5"	1.5"	1.5"		
Operating Pressure	27psi	30psi	30psi		
Test Start Time	0800	0900	0905		
Initial Pressure	60	60	60		
Initial Beaker Reading	0.0440	0.0440	0.0440		
Test End Time	0900	1000	1000		
Ending Pressure	60	60	60		
Ending Beaker Reading	0.0440	0.0440	0.0440		
Measure Leak Rate (GPH)	0	0	0		
Pass(P) Fail(F) or Inconclusive(I)	P	P	P		

PO BOX 335
CORYDON, IN 47112
812-946-6547
AJPETROLEUM@AOL.COM



A&J PETROLEUM

Spill Containment Device Test Results

Tank	1	2	3	4	5
Product	UNL1	PREM	DSL	UNL2	
Test Start Time	1200	1200	1200	1200	
Initial Reading (in)	12in	12in	12in	12in	
Test End Time	1300	1300	1300	1300	
Final Reading (in)	12in	12in	12in	12in	
Water Loss (in)	0	0	0	0	
Pass(P) or Fail(F)	P	P	P	P	

Please accept the above results with full confidence. Any questions or concerns with regards to the results or methods used should be directed to AJPETROLEUM@AOL.COM

John Ellett

UC2001KY866687