

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

AUG 26, 2025 6:14 PM

CSLD TEST RESULTS

AUG 26, 2025 6:14 PM

T 1:UNL 1

T 2:UNL 2

PROBE SERIAL NUM 170598

0.2 GAL/HR TEST

PER: AUG 26, 2025 INCR

T 3:PREM

PROBE SERIAL NUM 755283

0.2 GAL/HR TEST

PER: AUG 26, 2025 PASS

T 4:DSL

PROBE SERIAL NUM 753605

0.2 GAL/HR TEST

PER: AUG 26, 2025 PASS

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

AUG 26, 2025 6:14 PM

LIQUID STATUS

AUG 26, 2025 6:14 PM

L 1:UNL STP

SENSOR NORMAL

L 2:PREMSTP

SENSOR NORMAL

L 3:DSL STP

SENSOR NORMAL

L 4:UNL INT

SENSOR NORMAL

L 5:SPLIT INT

SENSOR NORMAL

* * * * * END * * * * *