

*** EMD ***
EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

FEB 23, 2025 6:27 PM

CSLD TEST RESULTS

FEB 23, 2025 6:27 PM

T 1:UNL 1

T 2:UNL 2

PROBE SERIAL NUM 170598

0.2 GAL/HR TEST

PER: FEB 23, 2025 INCR

T 3:PREM

PROBE SERIAL NUM 755283

0.2 GAL/HR TEST

PER: FEB 23, 2025 PASS

T 4:DSL

PROBE SERIAL NUM 753605

0.2 GAL/HR TEST

PER: FEB 23, 2025 PASS

***** END *****

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

FEB 23, 2025 6:27 PM

LIQUID STATUS

FEB 23, 2025 6:27 PM

L 1:UNL STP

SENSOR NORMAL

L 2:PREMSTP

SENSOR NORMAL

L 3:DSL STP

SENSOR NORMAL

L 4:UNL INT

SENSOR NORMAL

L 5:SPLIT INT

SENSOR NORMAL

***** END *****

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

FEB 23, 2025 6:27 PM

LEAK TEST REPORT

T 1:UNL 1
PROBE SERIAL NUM 170598

NO TEST DATA AVAILABLE

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

FEB 23, 2025 6:27 PM

LEAK TEST REPORT

T 2:UNL 2
PROBE SERIAL NUM 061470

NO TEST DATA AVAILABLE

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

FEB 23, 2025 6:27 PM

LEAK TEST REPORT

T 3:PREM
PROBE SERIAL NUM 755283

NO TEST DATA AVAILABLE

* * * * * END * * * * *

EXPO SAMPLE ST
1338 W SAMPLE ST
SOUTH BEND, IN

FEB 23, 2025 6:27 PM

LEAK TEST REPORT

T 4:DSL
PROBE SERIAL NUM 753605

NO TEST DATA AVAILABLE

* * * * * END * * * * *