



5296 Breakers Way, Carmel, IN 46033

Date 8/15/24

## PRODUCT LINE TEST

### Test Location Information

|         |              |
|---------|--------------|
| Name    | FID 16274    |
| Address | 170 S SR 135 |
| City    | Bargersville |
| Phone   |              |
| Contact |              |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### Applied Pressure

|        |
|--------|
| 50 psi |
|--------|

| #1                  | Product Type : Regular |     |        |     |     |
|---------------------|------------------------|-----|--------|-----|-----|
| TIME                | DATA                   | +/- | GPL    | RES | GPH |
| 11:40am             | 88                     | 0   | 0.0037 | 0   | 0   |
| 11:55am             | 88                     | 0   | 0.0037 | 0   | 0   |
| 12:10pm             | 88                     | 0   | 0.0037 | 0   | 0   |
|                     |                        |     | 0.0037 |     |     |
|                     |                        |     | 0.0037 |     |     |
|                     |                        |     | 0.0037 |     |     |
|                     |                        |     | 0.0037 |     |     |
| Final Result : Pass |                        |     |        |     |     |

| #2                  | Product Type : Premium |     |        |     |     |
|---------------------|------------------------|-----|--------|-----|-----|
| TIME                | DATA                   | +/- | GPL    | RES | GPH |
| 12:30pm             | 69                     | 0   | 0.0037 | 0   | 0   |
| 12:45pm             | 69                     | 0   | 0.0037 | 0   | 0   |
| 1:00pm              | 69                     | 0   | 0.0037 | 0   | 0   |
|                     |                        |     | 0.0037 |     |     |
|                     |                        |     | 0.0037 |     |     |
|                     |                        |     | 0.0037 |     |     |
|                     |                        |     | 0.0037 |     |     |
| Final Result : Pass |                        |     |        |     |     |

| #3                  | Product Type : Diesel |     |        |     |     |
|---------------------|-----------------------|-----|--------|-----|-----|
| TIME                | DATA                  | +/- | GPL    | RES | GPH |
| 1:35pm              | 55                    | 0   | 0.0037 | 0   | 0   |
| 1:50pm              | 55                    | 0   | 0.0037 | 0   | 0   |
| 2:05pm              | 55                    | 0   | 0.0037 | 0   | 0   |
|                     |                       |     | 0.0037 |     |     |
|                     |                       |     | 0.0037 |     |     |
|                     |                       |     | 0.0037 |     |     |
|                     |                       |     | 0.0037 |     |     |
| Final Result : Pass |                       |     |        |     |     |

| #4               | Product Type : |     |        |     |     |
|------------------|----------------|-----|--------|-----|-----|
| TIME             | DATA           | +/- | GPL    | RES | GPH |
|                  |                |     | 0.0037 |     |     |
|                  |                |     | 0.0037 |     |     |
|                  |                |     | 0.0037 |     |     |
|                  |                |     | 0.0037 |     |     |
|                  |                |     | 0.0037 |     |     |
|                  |                |     | 0.0037 |     |     |
|                  |                |     | 0.0037 |     |     |
| Final Result : . |                |     |        |     |     |



5296 Breakers Way, Carmel, IN 46033

Date 8/15/24

## PRODUCT LINE TEST

### Test Location Information

|         |              |
|---------|--------------|
| Name    | FID 16274    |
| Address | 170 S SR 135 |
| City    | Bargersville |
| Phone   |              |
| Contact |              |

### Technician Information

|        |             |
|--------|-------------|
| Name   | Josh Rider  |
| Cert # | UC202406986 |

### Applied Pressure

|        |
|--------|
| 50 psi |
|--------|

## FINAL REPORT

| SR. No. | Product Type | Result |
|---------|--------------|--------|
| 1       | Regular      | Pass   |
| 2       | Premium      | Pass   |
| 3       | Diesel       | Pass   |
| 4       |              | .      |
| 5       |              | .      |
| 6       |              | .      |

All three pumps do not have ball valves and all three pumps functional element did not work. Used silver bullet isolation plug in all three in order to test.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 