

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

Facility Name: Bargersville Country Mark	Owner: Bargersville Country Mark
Address: 170 S SR 135	Address: 170 S SR 135
City, State, Zip Code: Bargersville, IN 46106	City, State, Zip Code: Bargersville, IN 46106
Facility I.D. #: 16274	Phone #: 16274

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	Regular	Premium	Diesel			
Tank Number	1	2	3			
Tank Volume, gallons	8,000	8,000	6,000			
Tank Diameter, inches	96	96	96			
Overfill Prevention Device Brand	OPW	OPW	OPW			
Type of Overfill Device	ASD ☐	ASD ☐	ASD ☐	☐	☐	☐

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	No ☐	Yes ☐	Yes ☐				
2. Drop tube and float mechanisms free of debris?	☐	Yes ☐	Yes ☐	☐	☐	☐	☐
3. Float moves freely without binding and poppet moves into flow path?	☐	Yes ☐	Yes ☐	☐	☐	☐	☐
4. Bypass valve in the drop tube open and free of blockage (if present)?	☐	Yes ☐	Yes ☐	☐	☐	☐	☐
5. Flapper adjusted to shut off flow at 95% capacity?*	☐	Yes ☐	Yes ☐	☐	☐	☐	☐
6. Is Ball Float Present?	☐	☐	☐	☐	☐	☐	☐
7. Measured Auto Shut-Off Level							

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings vapor- tight and leak-free?	☐	☐	☐	☐	☐	☐	☐
2. Ball float cage free of debris?	☐	☐	☐	☐	☐	☐	☐
3. Ball free of holes and cracks and moves freely in cage?	☐	☐	☐	☐	☐	☐	☐
4. Vent hole in pipe open and near top of tank?	☐	☐	☐	☐	☐	☐	☐
5. Ball float pipe proper length to restrict flow at 90% capacity?*	☐	☐	☐	☐	☐	☐	☐
6. Ball Float removed from the tank?	☐	☐	☐	☐	☐	☐	☐
7. Ball Float Level							

A "No" to any item in Lines 1-5 indicates a test failure.

Test Results	Fail ☐	Pass ☐	Pass ☐				
--------------	-------------------------------	-------------------------------	-------------------------------	--	--	--	--

Comment: The three prongs that keep the drop tube sitting on the riser are inside of the riser and I cannot remove the drop tube. It is wedged into the riser by the three prongs.

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.
** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Tester's Name : Josh Rider

Tester's Signature : 