



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 8/15/24

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 16274
Address	170 S SR 135
City	Bargersville
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		
Dies	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	27	13	90 ml	189ml	2 sec	Pass 
2	Premium	27	26	100 ml	189ml	2 sec	Pass 
3	Diesel	26	16	120 ml	189ml	3 sec	Pass 
4					189ml	.	
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Technician Signature :

