

SUNOCO
170 ST RD 135
BARGERSVILLE IN

08/28/2024 6:19 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	NOT INSTALLED

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	TROUBLE

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

08/28/2024	4:40 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

08/01/2024	9:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

07/02/2024	11:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

06/02/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

05/03/2024	7:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

04/03/2024	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

03/04/2024	10:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

02/03/2024	10:22 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

01/04/2024	11:06 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

12/05/2023	10:49 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

11/05/2023	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

10/06/2023	11:35 PM
LEAK TEST	0,20 GPH
SLOPE	0,07 GPH

09/06/2023	10:44 PM
LEAK TEST	0,20 GPH
SLOPE	0,00 GPH

08/07/2023	7:15 PM
LEAK TEST	0,20 GPH
SLOPE	0,09 GPH

TANK 2

08/28/2024	3:17 AM
LEAK TEST	0,20 GPH
SLOPE	-0,07 GPH

08/24/2024	3:47 AM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH

07/24/2024	4:40 AM
LEAK TEST	0,20 GPH
SLOPE	0,10 GPH

07/09/2024	1:34 AM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

06/10/2024	4:58 AM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

05/13/2024	4:31 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

04/25/2024	4:23 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

03/26/2024	11:15 PM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH

02/25/2024	2:48 AM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

01/26/2024	2:56 AM
LEAK TEST	0,20 GPH
SLOPE	0,08 GPH

12/27/2023	11:28 PM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH

11/27/2023	3:36 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

10/29/2023	11:23 PM
LEAK TEST	0,20 GPH
SLOPE	0,07 GPH

10/07/2023	1:52 AM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH

09/10/2023	8:18 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

08/23/2023	4:45 AM
LEAK TEST	0,20 GPH
SLOPE	0,09 GPH

TANK 3

12/02/2023	1:04 PM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

11/07/2023	11:59 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

10/08/2023	11:04 PM
LEAK TEST	0,20 GPH
SLOPE	-0,00 GPH

09/08/2023	10:01 PM
LEAK TEST	0,20 GPH
SLOPE	0,01 GPH

08/09/2023	11:06 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH