

SUNOCO
170 ST RD 135
BARGERSVILLE IN

09/01/2024 7:09 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-RDM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	NOT INSTALLED

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	TROUBLE

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

09/01/2024	6:41 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

08/31/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH

08/01/2024	9:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

07/02/2024	11:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

06/02/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

05/03/2024	7:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

04/03/2024	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

03/04/2024	10:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

02/03/2024	10:22 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

01/04/2024	11:06 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

12/05/2023	10:49 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

11/05/2023 11:18 PM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

10/06/2023 11:35 PM
LEAK TEST 0,20 GPH
SLOPE 0,07 GPH

09/06/2023 10:44 PM
LEAK TEST 0,20 GPH
SLOPE 0,00 GPH

08/07/2023 7:15 PM
LEAK TEST 0,20 GPH
SLOPE 0,09 GPH

TANK 2

08/31/2024 5:13 AM
LEAK TEST 0,20 GPH
SLOPE -0,02 GPH

08/24/2024 3:47 AM
LEAK TEST 0,20 GPH
SLOPE -0,06 GPH

07/24/2024 4:40 AM
LEAK TEST 0,20 GPH
SLOPE 0,10 GPH

07/09/2024 1:34 AM
LEAK TEST 0,20 GPH
SLOPE -0,04 GPH

06/10/2024 4:58 AM
LEAK TEST 0,20 GPH
SLOPE -0,04 GPH

05/13/2024 4:31 AM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

04/25/2024 4:23 AM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

03/26/2024 11:15 PM
LEAK TEST 0,20 GPH
SLOPE -0,06 GPH

02/25/2024 2:48 AM
LEAK TEST 0,20 GPH
SLOPE 0,03 GPH

01/26/2024 2:56 AM
LEAK TEST 0,20 GPH
SLOPE 0,08 GPH

12/27/2023 11:28 PM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

11/27/2023 3:36 AM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

10/29/2023 11:23 PM
LEAK TEST 0,20 GPH
SLOPE 0,07 GPH

10/07/2023 1:52 AM
LEAK TEST 0,20 GPH
SLOPE 0,04 GPH

09/10/2023 8:18 AM
LEAK TEST 0,20 GPH
SLOPE 0,02 GPH

08/23/2023 4:45 AM
LEAK TEST 0,20 GPH
SLOPE 0,09 GPH

TANK 3

12/02/2023 1:04 PM
LEAK TEST 0,20 GPH
SLOPE -0,04 GPH

11/07/2023 11:59 PM
LEAK TEST 0,20 GPH
SLOPE -0,01 GPH

10/08/2023 11:04 PM
LEAK TEST 0,20 GPH
SLOPE -0,00 GPH

09/08/2023 10:01 PM
LEAK TEST 0,20 GPH
SLOPE 0,01 GPH

08/09/2023 11:06 PM
LEAK TEST 0,20 GPH
SLOPE 0,03 GPH