

SUNOCO
170 ST RD 135
BARGERSVILLE IN

01/29/2025

7:49 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	NOT INSTALLED

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

01/29/2025	1:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
01/28/2025	9:46 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
12/29/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/29/2024	11:30 PM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH
10/30/2024	9:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
09/30/2024	10:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
08/31/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
08/01/2024	9:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/02/2024	11:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
06/02/2024	11:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
05/03/2024	7:16 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
04/03/2024	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
03/04/2024	10:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

02/03/2024	10:22 PM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

01/04/2024	11:06 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

TANK 2

01/27/2025	2:28 AM
LEAK TEST	0,20 GPH
SLOPE	-0,03 GPH

01/16/2025	3:50 AM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

12/18/2024	3:18 AM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

11/18/2024	3:06 AM
LEAK TEST	0,20 GPH
SLOPE	-0,01 GPH

10/19/2024	4:40 AM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH

09/22/2024	11:05 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

08/24/2024	3:47 AM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH

07/24/2024	4:40 AM
LEAK TEST	0,20 GPH
SLOPE	0,10 GPH

07/09/2024	1:34 AM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

06/10/2024	4:58 AM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH

05/13/2024	4:31 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

04/25/2024	4:23 AM
LEAK TEST	0,20 GPH
SLOPE	0,02 GPH

03/26/2024	11:15 PM
LEAK TEST	0,20 GPH
SLOPE	-0,06 GPH

02/25/2024	2:48 AM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

01/26/2024	2:56 AM
LEAK TEST	0,20 GPH
SLOPE	0,08 GPH

TANK 3

01/29/2025	7:39 PM
LEAK TEST	0,20 GPH
SLOPE	-0,02 GPH

01/07/2025	7:52 PM
LEAK TEST	0,20 GPH
SLOPE	0,03 GPH

12/08/2024	11:11 PM
LEAK TEST	0,20 GPH
SLOPE	-0,08 GPH

11/08/2024	10:23 PM
LEAK TEST	0,20 GPH
SLOPE	0,08 GPH

10/09/2024	10:56 PM
LEAK TEST	0,20 GPH
SLOPE	-0,07 GPH

09/11/2024	4:50 AM
LEAK TEST	0,20 GPH
SLOPE	0,04 GPH

12/02/2023	1:04 PM
LEAK TEST	0,20 GPH
SLOPE	-0,04 GPH