

SUNOCO
170 ST RD 135
BARGERSVILLE IN

07/18/2025

1:30 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-RDM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	NOT INSTALLED

PROBES

PROBE 1	TROUBLE
PROBE 2	OPERATIONAL
PROBE 3	TROUBLE

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

03/20/2025	9:48 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH
02/27/2025	10:56 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
01/28/2025	9:46 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
12/29/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/29/2024	11:30 PM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH
10/30/2024	9:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
09/30/2024	10:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
08/31/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
08/01/2024	9:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
07/02/2024	11:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

TANK 2

07/17/2025	3:29 AM
LEAK TEST	0.20 GPH
SLOPE	0.10 GPH
07/11/2025	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
06/11/2025	1:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
05/15/2025	2:39 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
04/16/2025	11:02 PM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH
03/17/2025	11:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
02/15/2025	9:21 PM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

08/31/2024	0.20 GPH
LEAK TEST	0.00 GPH
SLOPE	11:28 PM
	0.20 GPH
	-0.00 GPH

08/01/2024	9:19 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

07/02/2024	11:31 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

07/17/2025	3:29 AM
LEAK TEST	0.20 GPH
SLOPE	0.10 GPH

07/11/2025	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

06/11/2025	1:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

06/15/2025	2:39 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

01/16/2025	11:02 PM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

03/17/2025	11:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/15/2025	9:21 PM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

01/16/2025	3:50 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

02/18/2024	3:18 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

01/18/2024	3:06 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

00/19/2024	4:40 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

03/22/2024	11:05 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

03/24/2024	3:47 AM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

07/24/2024	4:40 AM
LEAK TEST	0.20 GPH
SLOPE	0.10 GPH

07/09/2024	1:34 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

TANK 3

01/21/2025	12:25 PM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH

01/07/2025	11:27 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

03/08/2025	10:08 PM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

02/06/2025	11:25 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

01/07/2025	7:52 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

02/08/2024	11:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

01/08/2024	10:23 PM
LEAK TEST	0.20 GPH
SLOPE	0.08 GPH

00/09/2024	10:56 PM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

09/11/2024	4:50 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

12/02/2023	1:04 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH