

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 16274	Contact Number
Facility Name COUNTRYSTAR	Contact email
Address 170 S SR 135, Ragsdaleville	Date of Inspection 01/29/25
Operator on Duty Name C. H. H. H. H.	Name of the Person Conducting Inspection AKHIL SAKHARAN

Operator Training current	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	☒ MTG	☐ TIM	☐ SIR	☐ IC	☐ Other
Make and Model	FFS TS750				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☐ Yes	☒ No	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com