

SUNOCO
170 ST RD 135
BARGERSVILLE IN

03/12/2025 8:51 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	NOT INSTALLED

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

03/12/2025	8:33 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

02/27/2025	10:56 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

01/28/2025	9:46 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

12/29/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

11/29/2024	11:30 PM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH

10/30/2024	9:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

09/30/2024	10:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

08/31/2024	11:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH