

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	156 279	Contact Number	
Facility Name		Contact email	
Address	170 SCR 175 46106	Date of Inspection	09-19-2025
Operator on Duty Name		Name of the Person Conducting Inspection	Gurpreet

Operator Training current	Operator Training ☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form ☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Release Detection Method	Release Detection ☒ ATG ☐ CIM	Operator Notified	☐ SIR ☐ IC ☐ Other
Make and Model	TS-750 Tank Sentinel	Operator Notified	☐ Yes ☐ No
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	Spill Buckets ☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	Fill Ports ☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	Piping/STP Sumps ☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	Under Dispenser Containments (UDC) ☐ Yes ☒ No	Operator Notified	☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date

www.tanksdata.com