

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 16274

Contact Number

Facility Name BP

Contact email

Address 1705 SR 135, Bogersville,

Date of Inspection 05-22-25

Operator on Duty Name SW-46106

Name of the Person Conducting Inspection Nehan Singh

Operator Training current

Operator Training
☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Registration/Notification Form

Is Registration current with correct owner, operator etc.

☐ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Release Detection

Release Detection Method

☒ ATG ☐ TIM

☐ SIR

☐ IC

☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal
 Necessary Monthly Printout Taken

Spill Buckets

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☒ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified ☒ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

Piping/STP Sumps

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☒ Yes ☐ No

Under Dispenser Containments (UDC)

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com