

SUNOCO
170 ST RD 135
BARGERSVILLE IN

10/18/2025

8:28 AM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	NOT INSTALLED

PROBES

PROBE 1	TRouble
PROBE 2	TRouble
PROBE 3	TRouble

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

NO DATA

TANK 3

NO DATA

PASSED SCALD TESTS

TANK 1

03/20/2025	9:48 PM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

02/27/2025	10:56 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

01/28/2025	9:46 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

12/29/2024	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

11/29/2024	11:30 PM
LEAK TEST	0.20 GPH
SLOPE	0.07 GPH

10/30/2024	9:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

09/30/2024	10:13 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

TANK 2

08/26/2025	12:09 AM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

08/08/2025	3:44 AM
LEAK TEST	0.20 GPH
SLOPE	0.09 GPH

07/11/2025	11:18 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

06/11/2025	1:59 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

05/15/2025	2:39 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

04/16/2025	11:02 PM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

03/17/2025	11:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH

02/15/2025	9:21 PM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

01/16/2025	3:50 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

12/18/2024	3:18 AM
------------	---------