

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

DEC 20, 2024 5:33 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
DEC 16, 2024 1:30 AM

HEIGHT = 46.7 INCHES
WATER = 0.0 INCHES
TEMP = 43.5 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 7867.1 GAL
PERCENT VOLUME = 52.9

LEAK TEST RESULTS
RATE = -10.32 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

DEC 20, 2024 5:33 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
DEC 16, 2024 1:30 AM

HEIGHT = 24.7 INCHES
WATER = 0.0 INCHES
TEMP = 54.6 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 1075.2 GAL
PERCENT VOLUME = 21.1

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *