

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

NOV 10, 2024 5:06 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
NOV 4, 2024 1:30 AM

HEIGHT = 56.9 INCHES
WATER = 0.0 INCHES
TEMP = 58.6 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 9908.1 GAL
PERCENT VOLUME = 66.6

LEAK TEST RESULTS
RATE = -7.04 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

NOV 10, 2024 5:06 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
NOV 4, 2024 1:30 AM

HEIGHT = 29.7 INCHES
WATER = 0.0 INCHES
TEMP = 65.4 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 1400.5 GAL
PERCENT VOLUME = 27.5

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

* * * * * END * * * * *