

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

SEP 5. 2024 5:42 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
SEP 2. 2024 1:30 AM

HEIGHT = 43.0 INCHES
WATER = 0.0 INCHES
TEMP = 71.1 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 6945.5 GAL
PERCENT VOLUME = 46.7

LEAK TEST RESULTS
RATE = -5.16 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

SEP 5. 2024 5:42 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
SEP 2. 2024 1:30 AM

HEIGHT = 19.6 INCHES
WATER = 0.0 INCHES
TEMP = 73.1 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 745.6 GAL
PERCENT VOLUME = 14.7

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *