



5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 10/22/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 14296
Address	421 N Olive St
City	South Bend, IN 46628
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	33	32	130 ml	189ml	2 sec	Pass
2	Premium	29	28	210 ml	189ml	3 sec	Pass
3					189ml		.
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :