

5296 Breakers Way, Carmel, IN 46033

www.tanksdata.com
tanksdata@gmail.com
(317)-300-6065

Date

10/22/24

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE													
Facility Name: Citgo						owner: R&A Olive Property LLC							
Address: 421 N Olive St						Address: 51324 COLLEEN CT							
city, State, Zip Code: South Bend, IN 46628					7	city, state, Zip Code: Granger, IN, 46530							
Facility I.D. #: 14296						Phone #:							
This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.													
Product Grade	Regular		Premium										
Tank Number	1		2										
Tank Volume, gallons	15,000		6,000										
Tank Diameter, inches			96										
Overfill Prevention Device Brand OPW			OPW										
Type of Overfill Device	BF	•	BF	▼.		~		~		•			
		Δ	UTOMATIC SH	IUTO)FF I	DEVICE INSP	EC	CTION					
1. Drop tube removed from tank?		~		▼].		-	1	~		▼			
2. Drop tube and float mechanisms free of debris?		V		▼ .		~		~		▼			
3. Float moves freely without binding and poppet moves into flow path?		T		▼].		▼	Ī	▼	i.	▼	. 🔻		
4. Bypass valve in the drop tube open and free of blockage (if present)?		▼		▼ .		-	t	▼	i. i	▼			
5. Flapper adjusted to shut off flow at 95% capacity?*		—		▼ .		▼	l	▼		~	. 🔻		
6. Is Ball Float Present?		-		▼.		<u> </u>		_		▼			
7. Measured Auto Shut-Off Level		_					T		<u></u>				
A "No" to any item in Lines 1-5 indicate	es a test failure.												
			BALL FLOA	AT V	ALV	E INSPECTIO	N						
1. Tank top fittings vapor– tight and leak–free?		V		▼ .		-	1.	~		▼			
2. Ball float cage free of debris?		V		V		<u> </u>	Î.	▼		▼	. 🔻		
3. Ball free of holes and cracks and moves freely in cage?		V		▼.		▼	t	<u> </u>		V			
4. Vent hole in pipe open and near top of tank?		■		V			1	▼		V			
5. Ball float pipe proper length to restrict flow at 90% capacity?**		—		\		→	1	▼		<u> </u>	_		
6. Ball Float removed from the		—		—				_		<u> </u>			
7. Ball Fjoat Level	<u>'</u>		<u> </u>	_			1		<u> </u>				
A "No" to any item in Lines 1-5 indicates a test failure.													
-	Fail	~	Fail	-		•	1.	▼	1	•			
Comment: Could not access ball floats inside of vapor recovery.													
* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity. ** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.													

Tester's Signature : _

Josh Rider

Tester's Name :