

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

JAN 24, 2025 12:19 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
JAN 20, 2025 1:30 AM

HEIGHT = 34.6 INCHES
WATER = 0.0 INCHES
TEMP = 41.9 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 5286.4 GAL
PERCENT VOLUME = 35.5

LEAK TEST RESULTS
RATE = -12.90 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

JAN 24, 2025 12:19 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
JAN 20, 2025 1:30 AM

HEIGHT = 31.0 INCHES
WATER = 0.0 INCHES
TEMP = 46.9 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 1508.3 GAL
PERCENT VOLUME = 29.6

LEAK TEST RESULTS
RATE = -1.30 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *