

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

JUL 29, 2025 6:32 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
JUL 28, 2025 1:30 AM

HEIGHT = 48.6 INCHES
WATER = 0.0 INCHES
TEMP = 74.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 8104.9 GAL
PERCENT VOLUME = 54.5

LEAK TEST RESULTS
RATE = -8.75 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

JUL 29, 2025 6:32 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
JUL 28, 2025 1:30 AM

HEIGHT = 22.6 INCHES
WATER = 0.0 INCHES
TEMP = 72.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 929.4 GAL
PERCENT VOLUME = 18.3

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *