

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

JUN 27, 2025 4:52 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
JUN 23, 2025 1:30 AM

HEIGHT = 13.7 INCHES
WATER = 0.0 INCHES
TEMP = 66.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1383.3 GAL
PERCENT VOLUME = 9.3

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

JUN 27, 2025 4:52 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
JUN 23, 2025 1:30 AM

HEIGHT = 19.2 INCHES
WATER = 0.0 INCHES
TEMP = 64.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 731.4 GAL
PERCENT VOLUME = 14.4

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *