

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

MAY 30, 2025 3:53 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
MAY 26, 2025 1:30 AM

HEIGHT = 52.6 INCHES
WATER = 0.0 INCHES
TEMP = 55.9 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 9053.6 GAL
PERCENT VOLUME = 60.8

LEAK TEST RESULTS
RATE = -16.10 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

MAY 30, 2025 3:54 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
MAY 26, 2025 1:30 AM

HEIGHT = 22.3 INCHES
WATER = 0.0 INCHES
TEMP = 60.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 916.4 GAL
PERCENT VOLUME = 18.0

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *