

LEAK TEST STATUS:
TEST NOT IN PROGRESS

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

MAR 21, 2025 7:23 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
MAR 17, 2025 1:30 AM

HEIGHT = 33.1 INCHES
WATER = 0.0 INCHES
TEMP = 44.9 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 4952.0 GAL
PERCENT VOLUME = 33.3

LEAK TEST RESULTS
RATE = 0.01 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

MAR 21, 2025 7:23 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
MAR 17, 2025 1:30 AM

HEIGHT = 19.3 INCHES
WATER = 0.0 INCHES
TEMP = 48.1 F

TEST LENGTH = 4.0 HRS
STRT VOLUME = 743.7 GAL
PERCENT VOLUME = 14.6

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *