

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

AUG 26, 2025 5:41 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 426738

TEST STARTING TIME:
AUG 25, 2025 1:30 AM

HEIGHT = 26.0 INCHES
WATER = 0.0 INCHES
TEMP = 74.6 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3455.0 GAL
PERCENT VOLUME = 23.2

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *

OLIVE ONE STOP SHOP
421 N OLIVE ST
SOUTH BEND

AUG 26, 2025 5:41 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 426739

TEST STARTING TIME:
AUG 25, 2025 1:30 AM

HEIGHT = 18.4 INCHES
WATER = 0.0 INCHES
TEMP = 75.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 681.6 GAL
PERCENT VOLUME = 13.4

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW

* * * * * END * * * * *