

UST Facility I.D.(FID) # 17296	Contact Number
Facility Name CITGO	Contact email
Address 471N Olive St 46678	Date of Inspection 08-26-2025
Operator on Duty Name	Name of the Person Conducting Inspection Cuspreet

Operator Training		Operator Notified	
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No	<input type="radio"/> Yes <input type="radio"/> No	
Registration/Notification Form		Operator Notified	
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No	<input type="radio"/> Yes <input type="radio"/> No	
Release Detection		Operator Notified	
Release Detection Method	<input checked="" type="radio"/> ATG <input type="radio"/> CIM <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other		
Make and Model VRTLS-356			
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Spill Buckets		Operator Notified	
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Fill Ports		Operator Notified	
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Piping/STP Sumps		Operator Notified	
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Under Dispenser Containments (UDC)		Operator Notified	
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name
317-645-0215

tanksdata@gmail.com

Signature 

Date
www.tanksdata.com